

Wyniki - Zestawienie pomieszczeń

Symbol	Opis	$\theta_{int,H}$	A	A _u	V	Φ_{HL}
		°C	m ²	m ²	m ³	W
1	Wiatrolap	20,0	9,00	9,00	29,4	1037
2	Sala nr1	20,0	55,00	55,00	179,8	5681
3	Komunikacja	20,0	2,60	2,60	8,5	72
4	Komunikacja	2,0	5,90	5,90	19,3	390
5	WC	20,0	1,30	1,30	4,3	66
6	WC	20,0	1,10	1,10	3,6	57
7	Pom. tech.	20,0	1,80	1,80	5,9	48
8	Sala nr2	20,0	27,10	27,10	88,6	2383
9	Sala nr3	20,0	26,60	26,60	87,0	2372